

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Jack L. Fischer, A.I.A., Secretary

December 20, 2007

DEMA ENGINEERING CO. ENGINEERING SONE CHAN 10020 BIG BEND BLVD. ST.LOUIS MO 63122

Re: Description: PROPORTIONER

Manufacturer: DEMA ENGINEERING CO.

Product Name: FAUCET ADAPTER

Model Number(s): 68-4-2, 68-4-2A, 68-4-3A, 68-4-4, 68-4-4 AND 68-21

Product File No: 20070546

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2012.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed in conjunction with faucets manufactured by Chicago, Fisher, and T&S to allow for connection to DEMA Blend Center units with a 163AG and/or 164AG air-gap proportioners that comply with ch. Comm 82 and 84 of the Wis, Adm. Code.
- The NSF 51 hose that is used to connect the proportioner to this product must have a pressure rating equal to or greater than 100 pisg @ 180 degree F.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742 fax: 608-267-9566

e-mail: mike.beckwith@wi.gov

SBD-10564-E (N.10/97) File Ref: 07054602.DOC